



Notes:
 Dashed boxes indicate Aquaworx supplied equipment
 Install in accordance with NEC and local codes
 NEC 430-102. Requires Disconnecting Means for Motor Controllers
 Solid State Relays will have some leakage current
 A Redundant Off Float may be required by code in some areas
 Both pumps must have identical operating voltage

Typical 240V Installation

Typical 120V Installation, Aquaworx IPC-SF Sand Filter Controller

6 Business Park Road Old Saybrook, CT 6475 www.aquaworx.com Phone 877-278-2979		AQUAWORX by INFILTRATOR	
Sheet Title: IPC-D Controller Wiring Diagram		Sheet File Name: ipcsf_sch	Rev: 1
Aug 12, 2008 Rev. B BEL	Size: 11x17	Document Number: IPCSF-SCH-001	Rev: 1
Sheet Creation date: 10/20/99	Modification date: 08/12/2008	Sheet 1	of 1